Add: No.30 Henggangxia Industrial Zone, Xinqiao Village, Shajing Town, Shenzhen City, Guangdong Province, China 518125
Tel:(86) 755-27286968 Fax:(86) 755-27286928
E-mail: sparklehuang@163.com

http://www.ampleasia.com

## 630A Transformer Bushing

ATB-24/630/□ For 24kV 630A Applications ATB-36/630/□ For 36kV 630A Applications

#### **APPLICATION**

- For oil-insulated (R-temp, hydrocarbon, or silicon), apparatus, including switchgear, transformer, and capacitors.
- System voltage(Um) of 24kV and 36 kV.
- Continuous Current 630 A.
- For indoor and outdoor installations.
- Mounting in vertical or horizontal position.

#### **STANDARDS**

- meets the interface requirements of CENELEC HD506 S1, ANSI/IEEE 386, DIN 47636
- Has been tested with mating parts to IEC 60502-4 and CENELEC HD 629.1 S1

### **QUALITY ASSURANCE**

- Our manufacturing facility is registered to ISO 9001-2000 by third party audit.
- Required production test.
- 100% factory tested.

### **PACKAGING**

Supplied in a kit with all necessary parts.

# **Electrical Ratings**

Maximum system voltage(Um)	24kV	36kV
Impulse	125kV	170kV
AC withstand(1 Min)	54kV	81kV
P.D test at 30kV	<10pC	<10pC
Continuous current	630A	630A

Note: Rating are based on IEC standards and do not reflect maximum capability.



AMPLETEK POWER SYSTEM -----ISO 9001 REGISTERD