

## 12kV 630A Unscreened T-shaped Bushing boot

ALJQ-12/630/□

### Description

These are insulated T-shaped (Right angled) pre-molded unscreened silicone bushing boots suitable for use on 12kV Type "C" 630A bushings. It has a very compact gas-insulated secondary switchgear where the spacing between bushings is significantly reduced. The pre-molded shape ensures optimal/full contact over the entire Type "C" bushing profile thus improving its ability to eliminate unwanted leakage currents.



### Features

- . Quick and easy to install
- . Easy to remove and re-install
- . No specialized tools required
- . Compact profile provides for greater air clearance
- . In accordance with requirements of NRS012 /NRS053
- . Not tracking elastomeric housing offers excellent erosion resistance, dielectric properties and environmental resistance.
- . No slip/slide off the Type "C" bushings once installed.
- . Suitable to be used with all indoor terminations
- . Accommodates bulky torque shear lugs.

### Application (12kV only)

- . Compact Sf6 gas-insulated secondary switchgear (RMU's and Type B mini-substations)
- . Metal box filled with air
- . Distribution transformers
- . CT-VT metering Units


### Technical Data

Properties	Test Methods	Typical Values
Breakdown Strength	IEC 243	$\geq 20\text{kV/mm}$
Broken Extension Rate	ASTM D 2671	$\geq 300\%$
Tensile Strength	ASTM D 2671	$\geq 6\text{ MPa}$
Volume Conduct Rate	IEC 93	$\geq 10^{14} \Omega \cdot \text{m}$
Maximum System Voltage		17.5kV



# AMPLETEK Unscreened Silicone T-shaped Bushing Boots

## Dimension and accessories

All dimensions in mm






## Installation Diagram



# AMPLETEK Unscreened Silicone T-shaped Bushing Boots

## Test Record

 <p><b>AMPLETEK®</b> AMPLE Technology (Shenzhen) Co., LTD.</p>		<p>D building, Henggangxia Industrial Zone, Xinqiao Village, Shajing town, Shenzhen City, China Tel: (86)755-27286968 Fax: (86)755-27286928 www.ampleasia.com</p>																																															
<p align="center"><b>Test Record</b></p> <p align="right">Ref.: AP2014TR1031001 Date of Test: 2014-10-31</p> <p>1. Manufacturer: AMPLE Technology (Shenzhen) Co., LTD. 2. Description of Samples: 12kV Un-screened seperable connector boot 3. Quantity of Samples: 3pcs 4. Type of Samples: ALJQ-12/630 5. Test methods (Please see figure 1):</p>		 <p align="center"><b>Figure 1</b></p>																																															
<p><b>6. Test Sequence and Results</b></p> <table border="1"> <thead> <tr> <th>Test sequence</th> <th>Items</th> <th>Requirements</th> <th>Test methods of IEC 61442</th> <th>Results</th> <th>Remarks</th> </tr> </thead> <tbody> <tr> <td>1</td> <td>AC withstand voltage test</td> <td>No breakdown or no flashover shall occur at 39kV for 5 min</td> <td>Clause 4</td> <td>No breakdown or no flashover occurred on the combination samples at 39kV for 5 min</td> <td>PASS</td> </tr> <tr> <td>2</td> <td>Partial discharge test</td> <td>The magnitude of the discharge at 15kV shall not exceed 10pC</td> <td>Clause 7</td> <td>The magnitude of the discharge of the combination samples didn't exceed 3pC at 15kV</td> <td>PASS</td> </tr> <tr> <td>3</td> <td>Impulse withstand voltage test</td> <td>No breakdown shall occur at 10 positive and 10 negative impulses of 95kV</td> <td>Clause 6</td> <td>No breakdown occurred on the combination samples at 10 positive and 10 negative impulses of 95kV (See Annex A)</td> <td>PASS</td> </tr> </tbody> </table> <p>Annex A: (Unit kV)</p> <table border="1"> <tbody> <tr> <td>Positive polarity</td> <td>95.2</td> <td>95.6</td> <td>95.5</td> <td>96.0</td> <td>95.7</td> <td>95.6</td> <td>95.8</td> <td>95.9</td> <td>96.0</td> <td>95.5</td> </tr> <tr> <td>Negative polarity</td> <td>95.7</td> <td>95.6</td> <td>95.8</td> <td>95.9</td> <td>96.0</td> <td>95.5</td> <td>96.5</td> <td>95.9</td> <td>95.8</td> <td>96.2</td> </tr> </tbody> </table> <p align="center">  </p>				Test sequence	Items	Requirements	Test methods of IEC 61442	Results	Remarks	1	AC withstand voltage test	No breakdown or no flashover shall occur at 39kV for 5 min	Clause 4	No breakdown or no flashover occurred on the combination samples at 39kV for 5 min	PASS	2	Partial discharge test	The magnitude of the discharge at 15kV shall not exceed 10pC	Clause 7	The magnitude of the discharge of the combination samples didn't exceed 3pC at 15kV	PASS	3	Impulse withstand voltage test	No breakdown shall occur at 10 positive and 10 negative impulses of 95kV	Clause 6	No breakdown occurred on the combination samples at 10 positive and 10 negative impulses of 95kV (See Annex A)	PASS	Positive polarity	95.2	95.6	95.5	96.0	95.7	95.6	95.8	95.9	96.0	95.5	Negative polarity	95.7	95.6	95.8	95.9	96.0	95.5	96.5	95.9	95.8	96.2
Test sequence	Items	Requirements	Test methods of IEC 61442	Results	Remarks																																												
1	AC withstand voltage test	No breakdown or no flashover shall occur at 39kV for 5 min	Clause 4	No breakdown or no flashover occurred on the combination samples at 39kV for 5 min	PASS																																												
2	Partial discharge test	The magnitude of the discharge at 15kV shall not exceed 10pC	Clause 7	The magnitude of the discharge of the combination samples didn't exceed 3pC at 15kV	PASS																																												
3	Impulse withstand voltage test	No breakdown shall occur at 10 positive and 10 negative impulses of 95kV	Clause 6	No breakdown occurred on the combination samples at 10 positive and 10 negative impulses of 95kV (See Annex A)	PASS																																												
Positive polarity	95.2	95.6	95.5	96.0	95.7	95.6	95.8	95.9	96.0	95.5																																							
Negative polarity	95.7	95.6	95.8	95.9	96.0	95.5	96.5	95.9	95.8	96.2																																							

